

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

279
SSE
1/4-1/2
0.406 mi.
2144 ft.

VAULT 4081
602 SURF AVE
BROOKLYN, NY

NY Spills S117362861
N/A

Relative:
Higher

Actual:
4 ft.

SPILLS:

Name: VAULT 4081
Address: 602 SURF AVE
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 1406345 / 2017-06-27
Facility ID: 1406345
Facility Type: ER
DER Facility ID: 454838
Site ID: 499810
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2014-09-14
Investigator: RWAUSTIN
Referred To: Not reported
Reported to Dept: 2014-09-14
CID: Not reported
Water Affected: Not reported
Spill Source: Transformer
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2014-09-14
Spill Record Last Update: 2017-06-27
Spiller Name: ERT
Spiller Company: CONEDISON
Spiller Address: 4 IRVING PL
Spiller Company: 999
Contact Name: ERT
DEC Memo: "6/27/17 - Austin - 1/2 pint dielectric fluid leak on outside of aboveground vaulted transformer - Con Ed contained and cleaned up the spill, and repaired a leaking bushing - See document files for further information - Spill closed - end"
Remarks: "Half of a pint spilled to and is contained to the vault. Clean up is postponed due to unsafe conditions."

All Materials:

Site ID: 499810
Operable Unit ID: 1249219
Operable Unit: 01
Material ID: 2250780
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: .01
Units: G
Recovered: Not reported
Oxygenate: Not reported